


Office of the Executive Engineer
Public Health Engineering Department, Sasaram (Rohtas)

Divisional Laboratory:- Sasaram

(Values In mg /Lit. except pH. Otherwise mentioned)																			
Zone :- Patna								Division Name: SASARAM					Date:-28/04/2026						
Sl. No.	Block	Panchayat	Village	Name of Habitation/Ward No.	Location of Source	Parameters													
						pH	Turb	Ec	TDS	TH	Ca	Mg	Cl	Alka.	Fe	No3	So4	F	Total Coli.
1	Nokha	Nokha	Meyari Bazar, Rohtas	Sidheshwar Public School Meyari Bazar, Rotas	Sidheshwar Public School Meyari Bazar, Rotas	6.58	1	386	251	193	46	18.25	30	149	0.1	BDL	10	0.172	Negative
Desirable Limit						6.5-8.5	1	-	500	200	75.0	30.00	250	200	1	45	200	1	
Drinking Water Specification (Second Revision) IS 10500 /2012 Permissible limit in absence of alternate source						NR	5.0 NTU		2000	600	200	100	1000	600	NR	NR	400	1.5	


Note:- Sample collected By -School Staff

BDL- Below detection limit


28/04/2026

Chemist

P.H.Division.Sasaram


28/04/2026

Executive Engineer

P.H.Division.Sasaram